

Tennet

ONL 15-102

Stakeholder engagement and Consultation Process OWFs

Expert Meeting, 18.03.2015, Arnhem

Michiel Müller / Rob van der Hage



Welcome



Introduction and explanation on stakeholder process and expert meetings

Objective of the managed stakeholder engagement process



To ensure ...

- > the best possible preparation of TenneT for its role as the Dutch offshore grid operator
- > a decision process with respect to the development, design, planning, construction and operation of the offshore grid which is clear, transparent and with complete and in-depth consultation of all relevant stakeholders



through ...

- > a definition/development process of the offshore electrical infrastructure together with the stakeholders that ensures:
 - > transparency on key choices/decisions
 - > provision of a complete set of fact-based documentation that forms the basis of choices
 - > maximum consensus on these choices where possible
 - > transparency on projected cost and (future) cost reduction

where ...

- > TenneT takes a leadership role in realising the Energy Agreement
- > by listening to the stakeholders involved,
- > pro-actively contributing its knowledge and expertise,
- > incorporating input from the stakeholders, and
- > making final decisions in the interest of society

Consultation process



Selection of topics

Technical

- Voltage level
- Point of coupling
- SCADA, metering
- Redundancy

Planning

- Alignment


Legal

- ATO / REA

Other

- Innovation

Consultation process Offshore Windfarm Sector



- Website launched to support the consultation process, providing access to all relevant documents and opportunity for feedback.
- Agenda and background documents for next expert meeting provided two weeks prior to the meeting. Feedback enabled on website.
- Summary of expert meeting and feedback released after the expert meeting, including proposed next steps.

Expert meeting's topics rolling agenda



		nov	dec	jan	feb	mar	apr	may	jun	jul	sep	oct	nov		
T.1	Voltage level	I	I	I	I	D	D	N	C	C	C	C	C	I	I. Inform
T.2	# of J tubes / bays	I	I	I	I	D	N	C	C	C	C	C	C	D	D. Discuss
T.3	Point of Common Coupling	I	I	I	I	D	N	C	C	C	C	C	C	N	N. Notify
T.4	Access to platform	C	C	C	C	C	I	D	D	N	C	C	C	C	Closed
T.5	Operation of Bays	I	I	I	I	I	D	D	N	C	C	C	C	C	
T.6	Protection	I	I	I	I	I	D	D	N	C	C	C	C	C	
T.7	Implementation RfG code	I	I	I	I	I	D	N	C	C	C	C	C	C	
T.8	SCADA	I	I	I	I	I	D	D	N	C	C	C	C	C	
T.9	Metering	I	I	I	I	I	I	D	D	N	C	C	C	C	
T.10	Data links / communication	I	I	I	I	I	I	D	D	N	C	C	C	C	
T.11	Overplanting	I	I	I	I	I	D	D	N	C	C	C	C	C	
T.12	Redundancy / availability	C	C	C	C	C	I	D	N	C	C	C	C	C	
T.13	Installation interface management	C	C	C	C	C	C	I	D	D	D	N	C	C	
T.14	O&M interface management	C	C	C	C	C	C	I	D	D	D	N	C	C	
P.1	Planning	C	C	C	C	D	D	D	D	D	D	D	D	D	
L.1	ATO / REA	C	C	C	C	I	D	D	D	D	D	N	C	C	
L.2	Initial Investment Plan	C	C	C	C	C	C	I	I	I	N	C	C	C	
O.1	Innovation	C	C	C	C	C	N	N	C	C	C	C	C	C	
O.2	Stranded asset mitigation	C	C	I	I	I	I	D	D	D	N	C	C	C	

Agenda



WHEN	WHAT	TYPE OF SESSION
10.00-10.15	Welcome	Introduction
10.15-10.45	Introduction and explanation on stakeholder process and expert meetings Agenda for today	Presentation
10.45-11.15	General update on process	Presentation (inform only)
11.15-12.15	T1_Voltage level [D]	Discussion
12.15-12.45	Break & collect lunch	
12.45-13.05	T2_ # of J tubes / bays [D]	Discussion
13.05-13.25	T3_ Point of Common Coupling [D]	Discussion
13.25-13.45	L1_ ATO / REA [I]	Presentation
13.45-14.00	Break	
14.00-14.55	P1_Planning [D]	Discussion
14.55-15.00	Closure	Presentation
[N]	Notification session	
[D]	Discussion session	
[I]	Information session	



General update on process



Technical

- > Overall frame work - scenario EZ & initial investment plan
- > Basic design platform started
- > Focused on structuring transparent consultation process and topic definition/prioritisation
- > Ongoing: Preparation of internal documents and external reports for future consultation topics

Planning

- > Permitting: NRD finalised
- > Importance to align on overall planning of all involved stakeholders
- > Today: planning of consultation topics. Realisation planning in Expert Meeting April

Legal

- > Legal frame work ATO/REA
- > AMvB compensation



T1_Voltage level

Discussion




T1_Voltage level

Structure of the discussion

- (10 min) Clarification position TenneT
- (15 min) Questions & concerns - Report DNV-GL
- (10 min) Response & clarification - DNV-GL
- (15 min) Questions & concerns - Position paper TenneT
- (10 min) Response & clarification - TenneT

Input

- Previous Expert Meetings and Bi-lateral meetings
- External report DNV-GL
- Position paper TenneT (ONL15-058-T1_Voltage level_PP_v1)





Main considerations

- TenneT contributes to the overall cost reduction target, through standardisation of all 5 offshore platforms to be realised for the development of 3450 MW offshore wind, with a single platform serving concentrated large (700 MW) wind areas and use of technology that is ready for future large capacity wind turbines.
- Implementation of 66 kV infield cable voltage is considered technically feasible, with respect to both the cables, turbines and all connecting electrical equipment
- 66 kV operating systems are expected to become the cheapest option available, reducing cable length, number of J-tubes, installation work and losses with increasing wind farm size to 700 MW in the Dutch offshore wind tenders.
- Key cable manufacturers are currently in the process of getting 66 kV cables certified, and expected to finish certification in time for realisation of the first offshore wind tender. First cables are expected to come to the market in 2015.

Position: TenneT is inclined towards standardising the connection voltage level of the inter-array cables to the TenneT offshore transformer platform at 66 kV for all five platforms to be realised by TenneT up to 2023.

T1_Voltage level



Cost impact: high level breakdown

Quantitative	LCoE Impact	Uncertainty	Comment
Cost element Developer			
Wind turbines: transformer	0.4%	Low	Transformer costs expected to increase 40% - 50% (2). Transformer cost constitute ~2% of WTG CAPEX (3).
Wind turbines: switchgear	0.2%	Medium	Conservative increase in switchgear costs assumed of 50% (1). Switchgear ~1% of WTG CAPEX (3).
Array cable costs	0.3%	Medium	Increase in cable costs [EUR/m] of 10% (1).
Array cable length	-1.7%	Low	Decrease in cable length [km] of 30% (1).
Cost element TenneT			
Substation: Compensation equipment	0.1%	Low	Increase cost of reactive power compensation equipment of 50% (1). Compensation equipment constitute ~5% of Offshore Substation CAPEX (3).
Substation: Connection	0.0%	Medium	Switchgear worst case increase in costs assumed of 50% (2), however, since the number of required switchgear decreases, the cost increase is partly offset. The net effect is expected to be minimal (3).
Substation: J-tubes	0.0%	Low	Decrease in cost by decrease in number of J-tubes (from 28 to 16) (1,2,3)
Impact on yield			
Losses	-0.2%	Medium	Losses 33 kV 0.8%; losses 66 kV 0.55% from (1). Impact on LCoE directly related (conservatively value of -0.2% chosen) (3).
Society			
Borssele Alpha LCoE impact	-1.0%	Medium	Summation of the LCoE impact from separate items above (3).
Impact future years	-1.5% to -2.5%	Medium	Price for 66 kV equipment expected to decrease by 10% - 20% in the coming years (1). LCoE impact estimate (3).

Qualitative	LCoE Impact	Uncertainty	Comment
Technical	none	Low	No key technical issues expected hindering the implementation of 66 kV for offshore wind (1).
Logistics	Positive	Low	As it is possible to accommodate more power on a 66 kV circuit, quantity of array circuits entering the substation can be minimised. Fewer substations are therefore required in the 66 kV case, making a 700 MW offshore platform possible. (1)
Certification	Negative	Low	Key cable manufacturers are in the process of developing wet-design 66 kV cables and in the process of certification of these cables. Expected to be completed within 18 months under a program by the Carbon Trust (UK). (1) Amongst developers, different views exist with respect to the necessity of separate certification of turbines for the new 66 kV voltage level, as well as whether certification of
Market	Negative	Medium	Most market factor are considered as externalities (e.g. steel prices, many wind farms being realised at the same time etc.) and not included in LCoE calculations. The main market component which may have a direct impact on the cost levels for 66 kV relative to 33 kV, result from the number of suppliers that are able to deliver suitable turbines and cables. Most major turbine manufacturers are currently capable of supplying 66 kV turbines. The number of 66 kV cable suppliers may be limited to the larger companies. (3)
Financial	Negative	Medium	Financers have indicated no specific risk premium will be added if similar guarantees are given by cable suppliers for 33 and 66 kV. However, as 66 kV is a new technology, it is expected that some cost increase may result from additional uncertainties in supply and operation of new equipment. (4)

References: DNV GL report (1), TenneT internal (2), Ecofys internal (3), Market feedback (4)



Questions & concerns



Break & lunch



T2_ # of J tubes / bays

Discussion



T2_ # of J tubes / bays

Input

- Position paper TenneT (ONL15-060-T2_ J tubes_ bays_PP_v1)

Main considerations

- Maximum nominal current per string: The maximum nominal current for each 66 kV string/bay is selected to be 630 A (= 72 MVA) to ensure the availability of suitable cables and switchgear.
- Maximum active power per string: since the offshore wind farms are expected to contribute to the grid stability with reactive power, it is not possible to connect 72 MW to one string/bay.
- The number of strings should be such that on average there is 20% spare capacity to provide flexibility in wind turbine distribution.



T2_ # of J tubes / bays

Position:

- TenneT states that in case of **66 kV** inter-array cables (based on 64 MW per cable) a standard platform shall be equipped with 16 J-tubes (2x7 for PPM, 1 for test or spare, 1 for the connection to the neighbouring platform).
- TenneT states that in case of **33 kV** inter-array cables (based on 35 MW per cable) a standard platform shall be equipped with 28 J-tubes (2x13 for PPM, 1 for test or spare, 1 for the connection to the neighbouring platform).



Questions & concerns



T3_ Point of Common Coupling

Discussion



T3_ Point of Common Coupling

Input

- Position paper TenneT (ONL15-061-T3_Connection Point_PP_v1)

Main considerations

- TenneT will keep the same policy for customer connections of PPM.
- This, standardized by IEC 60859, defines a clear interface which is also applicable for responsibilities regarding the realisation phase, as well as the maintenance phase.
- It prevents different ownerships of the switchgear installation for the different functionalities: connection of PPMs, transformer feeders, possible reactive power compensation and coupling of bus bars.

Position: The connection point (CP) between the offshore power park module (PPM) and TenneT is specified at the cable termination of the inter-array cables and the switchgear installation on the platform.



L1_ATO / REA

Presentation



Break




P1_Planning

Discussion

NL Offshore wind: stakeholder interaction




ONL-15064 - v1




Stakeholder interaction tracks



Expert Meeting – 18 march 2015:








Roll-out planning Borssele Alpha


Doc ONL 15-026 v1.0
 For consultation
 Date: 20150129



■	Responsibility EZ
■	Responsibility OWF
■	Milestone TenneT
Milestones TenneT:	
P10: Projectplan	
P11: Decision design basis	
P20: Decision request for tenders	
P30: Decision contract award	
P500: Start Trial run (hot commissioning complete)	



Borssele Alpha planning




3 TenneT – Developer – RVO interaction detail



OWF

RVO



a

b

T.1	Voltage level
T.2	# of J tubes / bays
T.3	Point of Common Coupling
T.5	Operation of Bays
T.6	Protection
T.7	Implementation RfG code
T.8	SCADA
T.9	Metering
T.10	Data links / communication
T.11	Overplanting
T.12	Redundancy / availability
P.1	Planning
O.1	Innovation
O.2	Stranded asset mitigation
	Geophys / geotech data
	Concept site decision

T.4	Access to platform
T.13	Installation interface management
T.14	O&M interface management
P.1	Planning
L.1	ATO / REA
L.2	Initial Investment Plan
	Wind data
	Final site decision



What is needed for a successful tender?

- voltage level connection
- maximum transport capacity
- TenneT single line diagram
- geographical information (location platform, location J-tubes, cable routes, etc.)
- (technical) connection requirements (RfG, reactive power compensation, etc.),
- definition connection point (technical, location),
- planning TenneT




		nov	dec	jan	feb	mar	apr	may	jun	jul	sep	oct	nov		
T.1	Voltage level	Yellow				Green	Green	Blue						Yellow	I. Inform
T.2	# of J tubes / bays					Green	Blue							Green	D. Discuss
T.3	Point of Common Coupling	Yellow				Green	Blue							Blue	N. Notify
T.4	Access to platform						Yellow	Green	Green	Blue				Grey	Closed
T.5	Operation of Bays	Yellow					Green	Green	Blue						
T.6	Protection	Yellow					Green	Green	Blue						
T.7	Implementation RfG code	Yellow					Green	Blue							
T.8	SCADA	Yellow					Green	Green	Blue						
T.9	Metering	Yellow					Yellow	Green	Green	Blue					
T.10	Data links / communication	Yellow					Yellow	Green	Green	Blue					
T.11	Overplanting	Yellow					Green	Green	Blue						
T.12	Redundancy / availability						Yellow	Green	Blue						
T.13	Installation interface management							Yellow	Green	Green	Green	Blue			
T.14	O&M interface management							Yellow	Green	Green	Green	Blue			
P.1	Planning					Green	Green	Green	Green	Green	Green	Green	Green		
L.1	ATO / REA					Yellow	Green	Green	Green	Green	Green	Blue			
L.2	Initial Investment Plan							Yellow	Yellow	Yellow	Blue				
O.1	Innovation						Blue	Blue							
O.2	Stranded asset mitigation			Yellow	Yellow	Yellow	Yellow	Green	Green	Green	Blue				

This overview relates to topics for which an interface choice made by TenneT influences the design and/or business case of the project developers. Which topics are unidentified in this overview?

Please have a look at the planning of these topics over time. In case of any delays in this planning – which topic cannot be delayed since it will cause a full stop in your design planning?



Borssele Alpha planning





Closure

Thank you

